

CEDARWOOD ENVIRONMENTAL SERVICES

8-12 Dietz Street, Suite 303, Oneonta NY 13820 • Phone 607-441-3246 • FAX 607-441-3251

**TOWN OF ANDES, NY
TOWN BOARD MEETING
REPORT BY CEDARWOOD ENVIRONMENTAL SERVICES
November 9, 2020**

1. Water System

Daily usage of treated water from the water system averaged 17,400 gallons per day for the month of October 2020.

2. Plant Purchases

3. O&M

Changed some filters in October 2020.

4. Equipment

5. Distribution System

Repaired water line and replaced old lead line under Main St. that provides water to 40 Lee Lane. Work was done by Delaware Bulldozing at a cost of \$20,679.84.

6. Library Well

Ran well on October 8, 2020.

CEDARWOOD ENVIRONMENTAL SERVICES

8-12 Dietz Street, Suite 303, Oneonta NY 13820 • Phone 607-441-3246 • FAX 607-441-3251

**TOWN OF ANDES, NY
TOWN BOARD MEETING
REPORT BY CEDARWOOD ENVIRONMENTAL SERVICES
November 9, 2020**

1. WWTP Plant

Plant effluent flow averaged 43,000 gallons per day for the month of October 2020..

2. SPDES Compliance/NYSDEC, NYCDEP

The plant discharges treated effluent to the Tremper Kill Brook. The WWTP was in compliance for the month of October 2020.

3. Collection System.

Delaware Bulldozing repaired leak in sewer lateral at 103 Main St.at a cost of \$6,279.64.

4. Plant Purchases.

5. Plant O&M

All running well.

6. Plant Equipment

7. Gladstone Hollow Septic System